Date: October-29-18
To: Bidders for Norfolk County Bid No. HSS-NL-18-06
Natural Gas Commercial Dryer
From: Lynda Toft, Purchasing Agent
purchasing@norfolkcounty.ca
Subject: Addendum No. 3 (1 page))

# ADDENDUM No. 3

This Addendum shall form part of the Contract Documents.

**The Bidders should acknowledge receipt of this Addendum in their Submission**

1. **Question:**
   What is the size of the make-up air?

   **Answer:**
   The existing free area of air-supply opening for the dryers is 287.625in$^2$.

   Norview Lodge has two laundry rooms equipped with two large dryers and one small dryer in each room. Overall, the existing three dryers have a total BTUH rating of 374,000 in each laundry room. This consists of the two large dryers with a BTUH rating of 151,200 each and a small dryer that will be replaced in each laundry room with a current BTUH rating of 71,600.

End of Addendum



Accessible formats and communication supports available upon request.