



2019 Annual Drinking Water System Report

Port Rowan Drinking Water System

1. Introduction

The Corporation of Norfolk County has prepared this report to satisfy the requirements of Section 11 of Ontario Regulation (O. Reg.) 170/03. This annual report must be prepared no later than February 28 of each year.

This report covers the period from January 1, 2019 to December 31, 2019, and the information provided complies with the reporting requirements of O. Reg. 170/03 Section 11.

A summary of Port Rowan's Municipal Drinking Water System is outlined below:

Drinking Water System Number: 220000898

Drinking Water System Name: Port Rowan Drinking Water System

Drinking Water System Owner: Corporation of Norfolk County

Drinking Water System Category: Large Municipal Residential

2. Reporting Requirements under Section 11 – O. Reg. 170/03

Section 11 requires that the report include the following information relating to the period covered by the report. This includes:

- A statement of where a report prepared under Schedule 22 will be available for inspection by any member of the public during normal business hours without charge.
- A brief description of the drinking water system, including a list of water treatment chemicals used.
- Any major expenses incurred to install, repair or replace required equipment.



- A summary of any reports made to the Ministry of Environment, Conservation and Parks (MECP) for Adverse Water Quality Incidents (AWQI's).
- A summary of the results of tests performed under O. Reg. 170/03, an approval, the municipal drinking water licence or an order, including an Ontario Water Resources Act (OWRA) order.
- To describe any corrective actions taken

3. Evidence of Compliance

Availability of the Annual Report

In accordance with Section 11 O. Reg. 170/03, a copy of the annual report will be posted for each system by the end of February each year on the Norfolk County web site at norfolkcounty.ca. A Summary Report on regulatory compliance is required annually under Schedule 22 of Regulation 170/03 for each municipal drinking water system. This report summarizes any known failures to meet the requirements of the Safe Drinking Water Act, its duration and corrective measures. The reports are presented to Norfolk County Council for acceptance before March 31st each year. The reports are made available to the public in April on the Norfolk County web site noted above or by request from the Environmental Services Department. A copy of the annual report is available to the public, free of charge at the following locations as well:

183 Main Street of Delhi, Delhi ON

50 Colborne St., Simcoe, ON

185 Robinson St., Simcoe, ON

22 Albert St., Langton, ON

The Booth's Harbour Drinking Water system is privately operated distribution system (260049101) which receives a copy of the annual report yearly as required by Section 11 of O. Reg. 170/03.



Description of the Municipal Drinking Water System

The Port Rowan water system supplies drinking water to the communities of Port Rowan & St. Williams. The system also provides drinking water to a private distribution system, which is owned and operated by Booth's Harbour. This system services approximately 450 people, which includes a small subdivision and a Marina.

The Port Rowan system is owned by Norfolk County and the operating authority is Norfolk County's Environmental Services Department. The drinking water system, which includes the community of St. Williams, currently serves a population of approximately 2,300.

The water distribution system includes a 1,816 m³ elevated tank, which acts as a reservoir when the system requires larger amounts of water than the WTP can supply (such as firefighting and peak flows) and also helps to maintain a constant system pressure. There are approximately 85 fire hydrants and approximately 23,500 meters of watermain and transmission main ranging in diameter from 150 mm to 300 mm. The piping material consists of Polyvinyl Chloride (PVC) and ductile iron pipe. St. Williams and Booth's Harbour are connected to the Port Rowan system by a watermain that follows the Front Road. The community of St. Williams has a booster station, which increases the system pressure and also boosts the chlorine residual if required.

Water Treatment Chemicals

The following water treatment chemicals were used during the reporting period:

- Sodium Hypochlorite
- Carbon Dioxide
- Poly Aluminum Chloride

Significant Expenses Incurred

A brief summary of the major expenses incurred during the reporting period to install, repair or replace required equipment, and value of each, is included in Table 1.



Table 1 – Summary of Expenses Incurred

Activity	Cost Incurred (2019)
Port rowan to St. Williams Watermain Replacement (engineering)	\$14,800.00
Resurface Laneway at Water Tower	\$10,200.00
Port Rowan Water Treatment Plant Upgrades	\$34,800.00
General Operations Maintenance and Repair in Water Treatment Plants and Distribution System	\$64,900.00

4. Microbiological Testing

E. coli and Total Coliform

As per Schedule 10 of O. Reg. 170/03 – Microbiological Sampling and Testing, bacteriological tests for *E. coli* and total coliforms were performed weekly on the raw and treated water at the facilities and in the distribution system. The results from the 2019 sampling program for the Port Rowan Drinking Water System are shown in the table below.

Location	Number of Samples	Range of <i>E.coli</i> Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)
Raw	52	0 - 120	0 - 104000
Treated	52	0 - 0	0 - 0
Distribution	158	0 - 0	0 - 0

Heterotrophic Plate Count (HPC)

As per Schedule 10 of O. Reg. 170/03 - Microbiological Sampling and Testing, HPC analyses are required from the treated and distribution water. HPC tests are required weekly for treated water and for twenty five percent of the required distribution system bacteriological samples. Results over 500 colonies per 1 mL may indicate a change in water quality but is not considered an indicator of unsafe drinking water. The results from the 2019 HPC sampling program for the Port Rowan Drinking Water System are shown in the table below.



Location	Number of Samples	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Treated	52	52	<10 - 10
Distribution	158	53	<10 - 40

5. Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for sixty different chemical parameters. The latest results for these parameters are provided in Appendix A. The sampling frequency varies for the different types of water systems. If the concentration of the parameter is found to be above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by Regulation. No additional testing is required for the Port Rowan Drinking Water System.

6. Operational Monitoring

Operational checks including raw and treated water turbidity and treated and distribution free chlorine was conducted in accordance with Schedule 7 of Reg. O. 170/03.

Turbidity

The turbidity of the treated water is monitored continuously at each treatment plant; the turbidity of the raw water is checked on a weekly basis. Turbidity is measured in Nephelometric Turbidity Units (NTU). A summary of the 2019 turbidity monitoring results are provided in the table below.

Location	Number of Grab Samples	Range of Results	Unit of Measure
Turbidity Filter 1A	8760	0.01 – 0.76	NTU
Turbidity Filter 1B	8760	0.01 – 0.77	NTU
Turbidity Filter 2A	8760	0.01 – 0.40	NTU
Turbidity Filter 2B	8760	0.01 – 0.50	NTU



Chlorine Residual

In accordance with Schedule 7 of O. Reg. 170/03, free chlorine residuals in the treated water are monitored continuously at the point of entry to the distribution system at all water treatment plants and wells. The free chlorine in the water distribution system must be above 0.05 mg/L, if it is below this, it must be reported and corrective actions taken. The results from the 2019 chlorine residual monitoring program for the Port Rowan Drinking Water System are shown in the table below.

Location	Number of Grab Samples	Range of Results	Unit of Measure
Treatment Plant Chlorine Residual	8760	0.21 – 3.00	mg/L
Chlorine Residual Distribution System	523	0.08 – 1.84	mg/L

7. Adverse Results

In accordance with Schedule 16 – Reporting of Adverse Test Results and Other Problems of O. Reg. 170/03, there was one Adverse Water Quality Incident (AWQI) issued for the Port Rowan Drinking Water System. The following table describes the date the adverse occurred, the parameter, the result, the corrective action taken and the corrective action date.

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					



APPENDIX A: SUMMARY OF CHEMICAL RESULTS

UNDERSTANDING CHEMICAL TEST RESULTS

The following tables summarize the laboratory results of the chemical testing Norfolk County is required to complete. Different parameters are required to be tested for at different frequencies as noted below. Results are shown as concentrations with units of either milligrams per litre (mg/L) or micrograms per litre (ug/L). 1 mg/L is equal to 1000 ug/L. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in Municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. There were no additional testing or sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

The following tables summarize the Inorganic parameters tested for during the reporting period or the most recent sample results for the Port Rowan Drinking Water System.

Port Rowan

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	15/05/2019	0.09<MDL	ug/L	No
Arsenic	15/05/2019	0.2<MDL	ug/L	No
Barium	15/05/2019	34.7	ug/L	No
Boron	15/05/2019	17	ug/L	No
Cadmium	15/05/2019	0.003<MDL	ug/L	No
Chromium	15/05/2019	0.13	ug/L	No
Lead	Exempt			
Mercury	15/05/2019	0.01<MDL	ug/L	No
Selenium	15/05/2019	0.06	ug/L	No
Sodium	03/06/2015	17.0	mg/L	No
Fluoride	03/06/2015	0.08	mg/L	
Uranium	15/05/2019	0.092	ug/L	No
Nitrite	20/02/2018	0.003<MDL	mg/L	No
	15/05/2018	0.003<MDL	mg/L	No
	21/08/2018	0.003<MDL	mg/L	No
	18/11/2018	0.003<MDL	mg/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Nitrate	20/02/2018	2.21	mg/L	No
	15/05/2018	1.22	mg/L	No
	21/08/2018	0.056	mg/L	No
	18/11/2018	0.151	mg/L	No

The following tables summarize the Organic parameters tested for during the reporting period or the most recent sample results for Port Rowan.

Port Rowan

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	15/05/2019	0.02<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	15/05/2019	0.02	ug/L	No
Azinphos-methyl	15/05/2019	0.05<MDL	ug/L	No
Benzene	15/05/2019	0.32<MDL	ug/L	No
Benzo(a)pyrene	15/05/2019	0.004<MDL	ug/L	No
Bromoxynil	15/05/2019	0.33<MDL	ug/L	No
Carbaryl	15/05/2019	0.05<MDL	ug/L	No
Carbofuran	15/05/2019	0.01<MDL	ug/L	No
Carbon Tetrachloride	15/05/2019	0.17<MDL	ug/L	No
Chlorpyrifos	15/05/2019	0.02<MDL	ug/L	No
Diazinon	15/05/2019	0.02<MDL	ug/L	No
Dicamba	15/05/2019	0.20<MDL	ug/L	No
1,2-Dichlorobenzene	15/05/2019	0.41<MDL	ug/L	No
1,4-Dichlorobenzene	15/05/2019	0.36<MDL	ug/L	No
1,2-Dichloroethane	15/05/2019	0.35<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	15/05/2019	0.33<MDL		
Dichloromethane	15/05/2019	0.35<MDL	ug/L	No
2,4-Dichlorophenol	15/05/2019	0.15<MDL	ug/L	No
2,4-	15/05/2019	0.19<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl	15/05/2019	0.40<MDL	ug/L	No
Dimethoate	15/05/2019	0.06<MDL	ug/L	No
Diquat	15/05/2019	1<MDL	ug/L	No
Diuron	15/05/2019	0.03<MDL	ug/L	No
Glyphosate	15/05/2019	1<MDL	ug/L	No
Malathion	15/05/2019	0.02<MDL	ug/L	No
MCPA	15/05/2019	0.00012<MDL	mg/L	No
Metolachlor	15/05/2019	0.01<MDL	ug/L	No
Metribuzin	15/05/2019	0.02<MDL	ug/L	No
Monochlorobenzene	15/05/2019	0.3<MDL	ug/L	No
Paraquat	15/05/2019	1<MDL	ug/L	No
Pentachlorophenol	15/05/2019	0.15<MDL	ug/L	No
Phorate	15/05/2019	0.01<MDL	ug/L	No
Picloram	15/05/2019	1<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	15/05/2019	0.04<MDL	ug/L	No
Prometryne	15/05/2019	0.03<MDL	ug/L	No
Simazine	15/05/2019	0.01<MDL	ug/L	No
Terbufos	15/05/2019	0.01<MDL	ug/L	No
Tetrachloroethylene	15/05/2019	0.35<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	15/05/2019	0.20<MDL	ug/L	No
Triallate	15/05/2019	0.01<MDL	ug/L	No
Trichloroethylene	15/05/2019	0.44<MDL	ug/L	No
2,4,6-Trichlorophenol	15/05/2019	0.25<MDL	ug/L	No
Trifluralin	15/05/2019	0.02<MDL	ug/L	No
Vinyl Chloride	15/05/2019	0.17<MDL	ug/L	No
Total Haloacetic Acid	20/02/2018	20.4	ug/L	No
	15/05/2018	17.2	ug/L	
Average 19.1 ug/L	21/08/2018	23.4	ug/L	
	18/11/2018	15.50	ug/L	
THM Annual	20/02/2018	30	ug/L	No
Average 50 ug/L	15/05/2018	44	ug/L	
	21/08/2018	81	ug/L	



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
	18/11/2018	46	ug/L	

The following table summarizes the lead testing as set out in Schedule 15.1 of O. Reg. 170/03 during the reporting period.

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	Exempt		
Distribution	None. Next required sampling is Spring 2021.		