



# 2019 Annual Drinking Water System Report

## Simcoe Drinking Water System

---

### 1. Introduction

The Corporation of Norfolk County has prepared this report to satisfy the requirements of Section 11 of Ontario Regulation (O. Reg.) 170/03. This annual report must be prepared no later than February 28 of each year.

This report covers the period from January 1, 2019 to December 31, 2019, and the information provided complies with the reporting requirements of O. Reg. 170/03 Section 11.

A summary of Simcoe's Municipal Drinking Water System is outlined below:

Drinking Water System Number: 220000371

Drinking Water System Name: Simcoe Drinking Water System

Drinking Water System Owner: Corporation of Norfolk County

Drinking Water System Category: Large Municipal Residential

### 2. Reporting Requirements under Section 11 – O. Reg. 170/03

Section 11 requires that the report include the following information relating to the period covered by the report. This includes:

- A statement of where a report prepared under Schedule 22 will be available for inspection by any member of the public during normal business hours without charge.
- A brief description of the drinking water system, including a list of water treatment chemicals used.
- Any major expenses incurred to install, repair or replace required equipment.



- A summary of any reports made to the Ministry of Environment, Conservation and Parks (MECP) for Adverse Water Quality Incidents (AWQI's).
- A summary of the results of tests performed under O. Reg. 170/03, an approval, the municipal drinking water licence or an order, including an Ontario Water Resources Act (OWRA) order.
- To describe any corrective actions taken

### **3. Evidence of Compliance**

#### **Availability of the Annual Report**

In accordance with Section 11 O. Reg. 170/03, a copy of the annual report will be posted for each system by the end of February each year on the Norfolk County web site at [norfolkcounty.ca](http://norfolkcounty.ca). A Summary Report on regulatory compliance is required annually under Schedule 22 of Regulation 170/03 for each municipal drinking water system. This report summarizes any known failures to meet the requirements of the Safe Drinking Water Act, its duration and corrective measures. The reports are presented to Norfolk County Council for acceptance before March 31st each year. The reports are made available to the public in April on the Norfolk County web site noted above or by request from the Environmental Services Department. A copy of the annual report is available to the public, free of charge at the following locations as well:

183 Main Street of Delhi, Delhi, ON

50 Colborne St., Simcoe, ON

185 Robinson St., Simcoe, ON

22 Albert St., Langton, ON

#### **Description of the Municipal Drinking Water System**

The Simcoe water system supplies drinking water to the Community of Simcoe. The drinking water system currently serves a population of approximately 15,000.

The Cedar Street Well Field is located at 396 Cedar Street and consists of five wells, an infiltration gallery, a reservoir and a booster pumping station.



The Northwest drinking water system located on Fourteenth Street is a well-based supply consisting of two groundwater well sources, an iron and manganese removal plant and a reservoir.

The Chapel Street Well located at 260 Chapel Street also provides water to the Community of Simcoe.

The water distribution system includes a 3,400 m<sup>3</sup> elevated storage tank, which acts as a reservoir when the system requires larger amounts of water than the wells can supply (such as firefighting and peak flows) and also helps to maintain a constant system pressure. There are approximately 520 fire hydrants and approximately 108,500 meters of water main and transmission main ranging in size from 150 mm to 400mm in diameter. The piping material consists of cast iron, Polyvinyl Chloride (PVC) and ductile iron pipe.

## Water Treatment Chemicals

The following water treatment chemicals were used during the reporting period:

- Sodium Hypochlorite
- Sodium Silicate
- Hydrofluorosilicic Acid
- Poly Aluminum Chloride
- Sodium Permanganate

## Significant Expenses Incurred

A brief summary of the major expenses incurred during the reporting period to install, repair or replace required equipment, and value of each, is included in Table 1.

Table 1 – Summary of Expenses Incurred

Activity	Cost Incurred (2019)
<b>General Operations Maintenance and Repair in Water Treatment Plants and Distribution System</b>	\$180,563.00
<b>Well Rehabilitations</b>	\$171,700.00
<b>Utility Tractor</b>	\$35,300.00
<b>High Lift Pump #3 Rebuild</b>	\$40,345.00



## 4. Microbiological Testing

### *E. coli* and Total Coliform

As per Schedule 10 of O. Reg. 170/03 – Microbiological Sampling and Testing, bacteriological tests for *E. coli* and total coliforms were performed weekly on the raw and treated water at the facilities and in the distribution system. The results from the 2019 sampling program for the Simcoe Drinking Water System are shown in the table below.

Location	Number of Samples	Range of <i>E.coli</i> Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)
Raw Cedar St 1	0		
Raw Cedar St 2	50	0 – 0	0 - 6
Raw Cedar St 3	52	0 – 0	0 - 1
Raw Cedar St 4	51	0 – 0	0 - 15
Raw Cedar St 5	48	0 – 0	0 - 17
Infiltration Gallery	52	0 – 64	0 - 85
Raw Chapel St	53	0 – 0	0 - 0
Raw NW 2	51	0 – 0	0 - 6
Raw NW 3	49	0 – 0	0 - 0
Cedar Street Reservoir POE	52	0 – 0	0 – 0
Chapel Street Well POE	52	0 – 0	0 – 0
North West Reservoir POE	52	0 - 0	0 – 0
Distribution	327	0 - 0	0 - 0

### Heterotrophic Plate Count (HPC)

As per Schedule 10 of O. Reg. 170/03 - Microbiological Sampling and Testing, HPC analyses are required from the treated and distribution water. HPC tests are required weekly for treated water and for twenty five percent of the required distribution system bacteriological samples. Results over 500 colonies per 1 mL may indicate a change in water quality but is not considered an indicator of unsafe drinking water. The results



from the 2019 sampling program for the Simcoe Drinking Water System are shown in the table below.

Location	Number of Samples	Range of HPC Results (min #)-(max #)	Unit of Measure
Cedar Street Reservoir POE	52	<10 - 10	cfu/mL
Chapel Street Well POE	52	<10 – 2000	cfu/mL
North West Reservoir POE	52	<10 – 20	cfu/mL
Distribution	113	<10 – 50	cfu/mL

## 5. Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for sixty different chemical parameters. The latest results for these parameters are provided in Appendix A. The sampling frequency varies for the different types of water systems. If the concentration of the parameter is found to be above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by Regulation. Additional testing is required for the Simcoe Drinking Water System as required by the Municipal Drinking Water Licence for Sodium and Volatile Organic Compounds (VOC). The nitrates levels are about 50% of the MAC of 10 mg/L and are also monitored on a quarterly basis. The Chapel Street Well also has nitrate levels that are about 50% of the MAC of 10 mg/L and are monitored on a quarterly basis.

## 6. Operational Monitoring

Operational checks including raw and treated water turbidity and treated and distribution free chlorine was conducted in accordance with Schedule 7 of Reg. O. 170/03.

### Turbidity

The turbidity of the treated water is monitored continuously at each treatment plant; the turbidity of the raw water is checked on a weekly basis. Turbidity is measured in Nephelometric Turbidity Units (NTU). Under O. Reg. 170/03 turbidity in groundwater is



not reportable, however at it's desirable to have it <1NTU at the treatment plant and <5NTU in the distribution system. The results from the 2019 turbidity monitoring program for the Simcoe Drinking Water System are shown in the table below.

Location	Number of Grab Samples	Range of Results	Unit of Measure
Turbidity Cedar St Well#1 Raw	0	N/A	NTU
Turbidity Cedar St Well#2 Raw	227	0.05 – 0.64	NTU
Turbidity Cedar St Well#3 Raw	241	0.05 – 0.60	NTU
Turbidity Cedar St Well#4 Raw	234	0.06 – 0.98	NTU
Turbidity Cedar St Well#5 Raw	214	0.06 – 0.20	NTU
Turbidity NW Well #2 Raw	52	0.09 – 7.74	NTU
Turbidity NW Well #3 Raw	49	0.20 – 6.14	NTU
Turbidity Chapel St Raw	52	0.04 – 0.15	NTU
Turbidity NW Filter 1	8760	0.01 – 0.99	NTU
Turbidity NW Filter 2	8760	0.01 – 1.13	NTU
Turbidity NW Filter 3	8760	0.01 – 0.47	NTU

## Chlorine Residual

In accordance with Schedule 7 of O. Reg. 170/03, free chlorine residuals in the treated water are monitored continuously at the point of entry to the distribution system at all water treatment plants and wells. The free chlorine in the water distribution system must be above 0.05 mg/L, if it is below this, it must be reported and corrective actions taken. The results from the 2019 chlorine residual monitoring program for Simcoe Drinking Water System are shown in the table below.



Location	Number of Grab Samples	Range of Results	Unit of Measure
Chlorine Cedar St	8760		mg/L
Chlorine Chapel St	8760	0.12 – 4.53	mg/L
Chlorine NW Res.	8760	0.79 – 1.99	mg/L
Chlorine Residual Distribution System	692	0.14 – 1.60	mg/L

## Fluoride

Hydrofluosilicic acid is added for fluoridation at the Chapel St. Well and the water treatment plants. The fluoride residuals are taken daily at the well and the water treatment plants. The results from the 2019 fluoride residual monitoring program for Simcoe Drinking Water System are shown in the table below.

Location	Number of Grab Samples	Range of Results	Unit of Measure
Fluoride Cedar St	365	0.17 – 0.79	mg/L
Fluoride Chapel St	365	0.00 – 0.87	mg/L
Fluoride NW Res.	365	0.24 – 0.69	mg/L

## 7. Adverse Results

In accordance with Schedule 16 – Reporting of Adverse Test Results and Other Problems of O. Reg. 170/03, there was one Adverse Water Quality Incident (AWQI) issued for the Simcoe Drinking Water System. The following table describes the date the adverse occurred, the parameter, the result, the corrective action taken and the corrective action date.

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					



## APPENDIX A: SUMMARY OF CHEMICAL RESULTS

### UNDERSTANDING CHEMICAL TEST RESULTS

The following tables summarize the laboratory results of the chemical testing Norfolk County is required to complete. Different parameters are required to be tested for at different frequencies as noted below. Results are shown as concentrations with units of either milligrams per litre (mg/L) or micrograms per litre (ug/L). 1 mg/L is equal to 1000 ug/L. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in Municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. Additional testing is required for the Simcoe Drinking Water System as required by the Municipal Drinking Water Licence for Sodium and Volatile Organic Compounds (VOC). The following tables summarize the Inorganic parameters tested for during the reporting period or the most recent sample results for Simcoe Drinking Water.

#### Simcoe Cedar Street Reservoir

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	15/05/2019	0.09<MDL	ug/L	No
Arsenic	15/05/2019	0.2<MDL	ug/L	No
Barium	15/05/2019	74.4	ug/L	No
Boron	15/05/2019	28	ug/L	No
Cadmium	15/05/2019	0.003<MDL	ug/L	No
Chromium	15/05/2019	0.25	ug/L	No
Lead	Exempt			
Mercury	15/05/2019	0.01<MDL	ug/L	No
Selenium	15/05/2019	0.31	ug/L	No
Sodium	20/02/2018 15/05/2018 21/08/2018 18/11/2018	58.5 47.4 48.1 54.2	mg/L mg/L mg/L mg/L	Yes
Uranium	15/05/2019	0.795	ug/L	No
Fluoride				
Nitrite	20/02/2018 15/05/2018 21/08/2018	0.003<MDL 0.003<MDL 0.003<MDL	mg/L mg/L mg/L	No





Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
	18/11/2018	0.003<MDL	mg/L	
Nitrate	20/02/2018	6.87	mg/L	No
	15/05/2018	5.69	mg/L	
	21/08/2018	5.86	mg/L	
	18/11/2018	7.27	mg/L	

### Simcoe Chapel Street Well

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	15/05/2019	0.10	ug/L	No
Arsenic	15/05/2019	0.2<MDL	ug/L	No
Barium	15/05/2019	76.7	ug/L	No
Boron	15/05/2019	22	ug/L	No
Cadmium	15/05/2019	0.007	ug/L	No
Chromium	15/05/2019	0.48	ug/L	No
Lead		Exempt		
Mercury	15/05/2019	0.01<MDL	ug/L	No
Selenium	15/05/2019	0.23	ug/L	No
Sodium	03/06/2015	17.9	mg/L	No
Uranium	15/05/2019	0.477	ug/L	No
Fluoride	Daily			
Nitrite	20/02/2018	0.003<MDL	mg/L	No
	15/05/2018	0.003<MDL	mg/L	
	21/08/2018	0.003<MDL	mg/L	
	18/11/2018	0.003<MDL	mg/L	
Nitrate	20/02/2018	5.28	mg/L	No
	15/05/2018	5.31	mg/L	
	21/08/2018	5.60	mg/L	
	18/11/2018	5.6	mg/L	

### Simcoe Northwest Reservoir

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	15/05/2019	0.09<MDL	ug/L	No
Arsenic	15/05/2019	0.2<MDL	ug/L	No
Barium	15/05/2019	74.8	ug/L	No
Boron	15/05/2019	17	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Cadmium	15/05/2019	0.007	ug/L	No
Chromium	15/05/2019	0.13	ug/L	No
Lead	Exempt			
Mercury	15/05/2019	0.01<MDL	ug/L	No
Selenium	15/05/2019	0.12	ug/L	No
Sodium	03/06/2015	9.13	mg/L	No
Uranium	15/05/2019	0.595	ug/L	No
Fluoride	Daily			
Nitrite	20/02/2018	0.003<MDL	mg/L	No
	15/05/2018	0.003<MDL	mg/L	
	21/08/2018	0.003<MDL	mg/L	
	18/11/2018	0.003<MDL	mg/L	
Nitrate	20/02/2018	1.95	mg/L	No
	15/05/2018	1.93	mg/L	
	21/08/2018	2.02	mg/L	
	18/11/2018	2.21	mg/L	

The following tables summarize the Organic parameters tested for during the reporting period or the most recent sample results for the Simcoe Drinking Water System.

### Simcoe Cedar Street Reservoir

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	15/05/2019	0.02<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	15/05/2019	0.01<MDL	ug/L	No
Azinphos-methyl	15/05/2019	0.05<MDL	ug/L	No
Benzene	15/05/2019	0.32<MDL	ug/L	No
Benzo(a)pyrene	15/05/2019	0.004<MDL	ug/L	No
Bromoxynil	15/05/2019	0.33<MDL	ug/L	No
Carbaryl	15/05/2019	0.05<MDL	ug/L	No
Carbofuran	15/05/2019	0.01<MDL	ug/L	No
Carbon Tetrachloride	15/05/2019	0.17<MDL	ug/L	No
Chlorpyrifos	15/05/2019	0.02<MDL	ug/L	No
Diazinon	15/05/2019	0.02<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Dicamba	15/05/2019	0.20<MDL	ug/L	No
1,2-Dichlorobenzene	15/05/2019	0.41<MDL	ug/L	No
1,4-Dichlorobenzene	15/05/2019	0.36<MDL	ug/L	No
1,2-Dichloroethane	15/05/2019	0.35<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	15/05/2019	0.33<MDL		
Dichloromethane	15/05/2019	0.35<MDL	ug/L	No
2,4 Dichlorophenol	15/05/2019	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	15/05/2019	0.19<MDL	ug/L	No
Diclofop-methyl	15/05/2019	0.40<MDL	ug/L	No
Dimethoate	15/05/2019	0.03<MDL	ug/L	No
Diquat	15/05/2019	1<MDL	ug/L	No
Diuron	15/05/2019	0.03<MDL	ug/L	No
Glyphosate	15/05/2019	1<MDL	ug/L	No
Malathion	15/05/2019	0.02<MDL	ug/L	No
MCPA	15/05/2019	0.00012<MDL	mg/L	No
Metolachlor	15/05/2019	0.01<MDL	ug/L	No
Metribuzin	15/05/2019	0.02<MDL	ug/L	No
Monochlorobenzene	15/05/2019	0.3<MDL	ug/L	No
Paraquat	15/05/2019	1<MDL	ug/L	No
Pentachlorophenol	15/05/2019	0.15<MDL	ug/L	No
Phorate	15/05/2019	0.01<MDL	ug/L	No
Picloram	15/05/2019	1<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	15/05/2019	0.04<MDL	ug/L	No
Prometryne	15/05/2019	0.03<MDL	ug/L	No
Simazine	15/05/2019	0.01<MDL	ug/L	No
Terbufos	15/05/2019	0.01<MDL	ug/L	No
Tetrachloroethylene	15/05/2019	0.35<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	15/05/2019	0.20<MDL	ug/L	No
Triallate	15/05/2019	0.01<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Trichloroethylene	15/05/2019	0.44<MDL	ug/L	No
2,4,6-Trichlorophenol	15/05/2019	0.25<MDL	ug/L	No
Trifluralin	15/05/2019	0.02<MDL	ug/L	No
Vinyl Chloride	15/05/2019	0.17<MDL	ug/L	No

### Chapel Street Well

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	15/05/2019	0.02<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	15/05/2019	0.01<MDL	ug/L	No
Azinphos-methyl	15/05/2019	0.05<MDL	ug/L	No
Benzene	15/05/2019	0.32<MDL	ug/L	No
Benzo(a)pyrene	15/05/2019	0.004<MDL	ug/L	No
Bromoxynil	15/05/2019	0.33<MDL	ug/L	No
Carbaryl	15/05/2019	0.05<MDL	ug/L	No
Carbofuran	15/05/2019	0.01<MDL	ug/L	No
Carbon Tetrachloride	15/05/2019	0.17<MDL	ug/L	No
Chlorpyrifos	15/05/2019	0.02<MDL	ug/L	No
Diazinon	15/05/2019	0.02<MDL	ug/L	No
Dicamba	15/05/2019	0.20<MDL	ug/L	No
1,2-Dichlorobenzene	15/05/2019	0.41<MDL	ug/L	No
1,4-Dichlorobenzene	15/05/2019	0.36<MDL	ug/L	No
1,2-Dichloroethane	15/05/2019	0.35<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	15/05/2019	0.33<MDL		
Dichloromethane	15/05/2019	0.35<MDL	ug/L	No
2-4 Dichlorophenol	15/05/2019	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	15/05/2019	0.19<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Diclofop-methyl	15/05/2019	0.40<MDL	ug/L	No
Dimethoate	15/05/2019	0.03<MDL	ug/L	No
Diquat	15/05/2019	1<MDL	ug/L	No
Diuron	15/05/2019	0.03<MDL	ug/L	No
Glyphosate	15/05/2019	1<MDL	ug/L	No
Malathion	15/05/2019	0.02<MDL	ug/L	No
MCPA	15/05/2019	0.00012<MDL	mg/L	No
Metolachlor	15/05/2019	0.01<MDL	ug/L	No
Metribuzin	15/05/2019	0.02<MDL	ug/L	No
Monochlorobenzene	15/05/2019	0.3<MDL	ug/L	No
Paraquat	15/05/2019	1<MDL	ug/L	No
Pentachlorophenol	15/05/2019	0.15<MDL	ug/L	No
Phorate	15/05/2019	0.01<MDL	ug/L	No
Picloram	15/05/2019	1<MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	15/05/2019	0.04<MDL	ug/L	No
Prometryne	15/05/2019	0.03<MDL	ug/L	No
Simazine	15/05/2019	0.01<MDL	ug/L	No
Terbufos	15/05/2019	0.01<MDL	ug/L	No
Tetrachloroethylene	15/05/2019	0.35<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	15/05/2019	0.20<MDL	ug/L	No
Triallate	15/05/2019	0.01<MDL	ug/L	No
Trichloroethylene	15/05/2019	0.44<MDL	ug/L	No
2,4,6-Trichlorophenol	15/05/2019	0.25<MDL	ug/L	No
Trifluralin	15/05/2019	0.02<MDL	ug/L	No
Vinyl Chloride	15/05/2019	0.17<MDL	ug/L	No

### Simcoe Northwest Reservoir

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor	15/05/2019	0.02<MDL	ug/L	No
Atrazine + N-dealkylated metabolites	15/05/2019	0.01<MDL	ug/L	No
Azinphos-methyl	15/05/2019	0.05<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Benzene	15/05/2019	0.32<MDL	ug/L	No
Benzo(a)pyrene	15/05/2019	0.004<MDL	ug/L	No
Bromoxynil	15/05/2019	0.33<MDL	ug/L	No
Carbaryl	15/05/2019	0.05<MDL	ug/L	No
Carbofuran	15/05/2019	0.01<MDL	ug/L	No
Carbon Tetrachloride	15/05/2019	0.17<MDL	ug/L	No
Chlorpyrifos	15/05/2019	0.02<MDL	ug/L	No
Diazinon	15/05/2019	0.02<MDL	ug/L	No
Dicamba	15/05/2019	0.20<MDL	ug/L	No
1,2-Dichlorobenzene	15/05/2019	0.41<MDL	ug/L	No
1,4-Dichlorobenzene	15/05/2019	0.36<MDL	ug/L	No
1,2-Dichloroethane	15/05/2019	0.35<MDL	ug/L	No
1,1-Dichloroethylene (vinylidene chloride)	15/05/2019	0.33<MDL		
Dichloromethane	15/05/2019	0.35<MDL	ug/L	No
2-4 Dichlorophenol	15/05/2019	0.15<MDL	ug/L	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	15/05/2019	0.19<MDL	ug/L	No
Diclofop-methyl	15/05/2019	0.40<MDL	ug/L	No
Dimethoate	15/05/2019	0.03<MDL	ug/L	No
Diquat	15/05/2019	1<MDL	ug/L	No
Diuron	15/05/2019	0.03<MDL	ug/L	No
Glyphosate	15/05/2019	1<MDL	ug/L	No
Malathion	15/05/2019	0.02<MDL	ug/L	No
MCPA	15/05/2019	0.00012<MDL	mg/L	No
Metolachlor	15/05/2019	0.01<MDL	ug/L	No
Metribuzin	15/05/2019	0.02<MDL	ug/L	No
Monochlorobenzene	15/05/2019	0.3<MDL	ug/L	No
Paraquat	15/05/2019	1<MDL	ug/L	No
Pentachlorophenol	15/05/2019	0.15<MDL	ug/L	No
Phorate	15/05/2019	0.01<MDL	ug/L	No
Picloram	15/05/2019	1<MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Polychlorinated Biphenyls(PCB)	15/05/2019	0.04<MDL	ug/L	No
Prometryne	15/05/2019	0.03<MDL	ug/L	No
Simazine	15/05/2019	0.01<MDL	ug/L	No
Terbufos	15/05/2019	0.01<MDL	ug/L	No
Tetrachloroethylene	15/05/2019	0.35<MDL	ug/L	No
2,3,4,6-Tetrachlorophenol	15/05/2019	0.20<MDL	ug/L	No
Triallate	15/05/2019	0.01<MDL	ug/L	No
Trichloroethylene	15/05/2019	0.44<MDL	ug/L	No
2,4,6-Trichlorophenol	15/05/2019	0.25<MDL	ug/L	No
Trifluralin	15/05/2019	0.02<MDL	ug/L	No
Vinyl Chloride	15/05/2019	0.17<MDL	ug/L	No
Total Haloacetic Acid	20/02/2018	5.3<MDL	ug/L	No
Average below detection 5.3 ug/L	15/05/2018	5.3<MDL	ug/L	
	21/08/2018	5.3<MDL	ug/L	
	18/11/2018	5.3<MDL	ug/L	
THM Annual Average 32 ug/L	20/02/2018	29	ug/L	No
	15/05/2018	31	ug/L	
	21/08/2018	37	ug/L	
	18/11/2018	31	ug/L	

The following table summarizes the lead testing as set out in Schedule 15.1 of O. Reg. 170/03 during the reporting period.

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	Exempt		
Distribution	None. Next required sampling is Spring 2021.		