



Date: May-16-19
To: Bidders for Norfolk County Bid No. PW-E-19-42
Delhi Wells 3A & 3B Upgrades
From: Scott Zerbes, Project Manager, Public Works
Scott.zerbes@norfolkcounty.ca
Subject: Addendum No. 1 (2 pages plus 2 pages of attachments)

ADDENDUM No. 1

This Addendum shall form part of the Contract Documents.

The Bidders should acknowledge receipt of this Addendum on the Submission Form – Appendix A.

Clarification OF THE TENDER DOCUMENT

It should be clarified that the installation of the pumps and the pitless units must be carried out by a licensed Ontario Water Well Contractor and Licensed Ontario Water Well Technicians in accordance with Ontario Regulation 903. This will include disinfection of the well and pumping equipment and submission of a revised Water Well Record to the MOECC. **Note:** The Ontario Water Well Records for Wells 3A and 3B will be emailed to Bidders who attended the Mandatory pre-bid information meeting).

Clarification OF THE TENDER DOCUMENT

It should be clarified that the warranty period for the contract is 24 months. All references to 12 months shall be disregarded.

Mandatory Pre-Bid Meeting

Sign-in sheet is attached with the list of eligible bidders. Refer to the attached Mandatory Pre-Bid Meeting Sign-In Sheet.

QUESTIONS AND ANSWERS

1. **Question:**

Section 11318 2.0.6 C - indicates the drop pipe shall be 19mm diameter. Drop Pipe diameters are correct in the conditions of service table. Please confirm.

Answer:

Drop pipe sizes to be per the conditions of service table.

2. Question:

Section 11318 2.0.7 - a surface plate is not required with a MAASS Model MB Heavy Duty Pitless Unit. Please confirm.

Answer:

Confirmed, surface plate not required.

3. Question:

Section 11318 2.1.0 - Are PT100 temperature sensing bolts required for the submersible motors?

Answer:

Not required.

4. Question:

Please clarify the following Specifications Section 02600 yard piping 2.02 D – states WM PVC DR 18, as well pipe schedule 2.08 states pipe joint type is Mechanical Joint Restrained. Drawing notes state on G101 that pipe is to be Fusible brute Pvc by ipex. Please confirm pipe to be used as well as fittings for that pipe.

Answer:

Note on Drawing G101 pertains only to the section of pipe identified which passes through the abandoned tile bed.

End of Addendum

Attachments:



Mandatory Pre-Bid Meeting Sign-In Sheet




Mandatory Pre-Bid Meeting Sign-In Sheet

Document Name:	Delhi Wells 3A & 3B Upgrades	Document Number:	PW-E-19-42
Meeting Date:	May 15, 2019	Time:	2pm
		Location:	2497 Windham West Quarter Line Road, Delhi

Company Name	Representative's Name	Representative's Signature	Contact Information		Business Card
			Phone:	Fax:	
Robert B Somerville	Scott Harrison		416-540-1159		
			Email: sharrison@rbsomerville.com		
CONTRACT DAILLING	MIC PATERAK		519 217 1293		
			Email: PATRICK@CDPGEOTHERMAL.ca		
K&L Construction	MARISSA JOHNSON		519-472-7164		
			Email: estimating@kandlconstruction.com		
REID + DELEUVE CONTRACTORS	GREG DELEUVE		519-688-2600		
			Email: gregd@reid-deleuve.com		
Hollen Controls Ltd.	Adrian Rombouts		519 282 6280		
			Email: adrian.rombouts@hpowergroup.com		
H2 ONTARIO INC	TREVOR UHRIG		519-662-1134	519-662-1135	
			Email: tuhriq@h2ontario.com		
FINNBILT GENERAL CONTRACTING LIMITED	KELLY VAN BAKEL		519 272-1622	519 272 7062	
			Email: jfinnie@finnbilt.ca		

Company Name	Representative's Name	Representative's Signature	Contact Information			Business Card
W. O. HOPPER & SONS LTD.	RON HOPPER		Phone: 888 522 1737	Fax: 522 0606		✓
XTERRA	ED JONES		Phone: 226 791 -8335	Fax:		✓
			Email: WDHOPPER@TCC.ON.CA			
			Email: ed@xterraconstruction.ca.			
			Phone:	Fax:		
			Email:			
			Phone:	Fax:		
			Email:			
			Phone:	Fax:		
			Email:			
			Phone:	Fax:		
			Email:			
			Phone:	Fax:		
			Email:			

	Name	Signature	Company or Department/Division
Meeting Coordinator:	Phil Spencer		
Staff in Attendance:	Scott Zerbes		Engineering
	Jeff Demoulemeister		
	Dave Graham		