

Date: September-20-19  
To: Bidders for Norfolk County Bid No. PW-FAC-19-15  
Metal Roof Replacement – Courtland Operations Facility  
From: Dave Fleming, Facilities Technologist, Public Works  
dave.fleming@norfolkcounty.ca  
Subject: Addendum No. 1 (1 page)

## **ADDENDUM No. 1**

This Addendum shall form part of the Contract Documents.

**The Bidders should acknowledge receipt of this Addendum on the Submission Form – Appendix A.**

**The date of closing of this tender shall be extended by one week from  
Tuesday, September-24-19 to:  
Tuesday, October-01-19**

**1. Question:**

Is the R-Mer Span Structural Standing Seam Roof System by Garland an approved alternate?

**Answer:**

Yes, it is an approved alternate.

**2. Delete:**

Technical Sections – Standing Seam Sheet Metal Roofing - Section 2.1  
Material, Item #15 – Gutter and Hangers: New Required

**Replace with:**

Technical Sections – Standing Seam Sheet Metal Roofing - Section 2.1  
Material, Item #15 – Gutter, Downspouts and Hangers/Brackets:

To provide minimum 0.85 mm (0.034 in. – 22 gauge) thick prefinished metal gutter, hangers, brackets and fasteners; all to be designed by Professional Engineer licensed in the Province of Ontario. All joints to be watertight.

Gutter to be 'rectangular' as per SMACNA, Figure 1-2, Style I.

New downspouts to rectangular to accommodate gutter water flow.

End of Addendum

Page 1 of 1