



# 2021 Annual Drinking Water System Report

## Port Dover Drinking Water System

---

### 1. Introduction

The Corporation of Norfolk County has prepared this report to satisfy the requirements of Section 11 of Ontario Regulation (O. Reg.) 170/03. This annual report must be prepared no later than February 28 of each year.

This report covers the period from January 1, 2021 to December 31, 2021, and the information provided complies with the reporting requirements of O. Reg. 170/03 Section 11.

A summary of Port Dover's Municipal Drinking Water System is outlined below:

Drinking Water System Number: 220000399

Drinking Water System Name: Port Dover Drinking Water System

Drinking Water System Owner: Corporation of Norfolk County

Drinking Water System Category: Large Municipal Residential

### 2. Reporting Requirements under Section 11 – O. Reg. 170/03

Section 11 requires that the report include the following information relating to the period covered by the report. This includes:

- A statement of where a report prepared under Schedule 22 will be available for inspection by any member of the public during normal business hours without charge.
- A brief description of the drinking water system, including a list of water treatment chemicals used.
- Any major expenses incurred to install, repair or replace required equipment.



- A summary of any reports made to the Ministry of Environment, Conservation and Parks (MECP) for Adverse Water Quality Incidents (AWQI's).
- A summary of the results of tests performed under O. Reg. 170/03, an approval, the municipal drinking water licence or an order, including an Ontario Water Resources Act (OWRA) order.
- To describe any corrective actions taken

### **3. Evidence of Compliance**

#### **Availability of the Annual Report**

In accordance with Section 11 O. Reg. 170/03, a copy of the annual report will be posted for each system by the end of February each year on the Norfolk County web site at [norfolkcounty.ca](http://norfolkcounty.ca). A Summary Report on regulatory compliance is required annually under Schedule 22 of Regulation 170/03 for each municipal drinking water system. This report summarizes any known failures to meet the requirements of the Safe Drinking Water Act, its duration and corrective measures. The reports are presented to Norfolk County Council for acceptance before March 31st each year. The reports are made available to the public in April on the Norfolk County web site noted above or by request from the Environmental Services Department. A copy of the annual report is available to the public, free of charge at the following locations as well:

185 Robinson St., Simcoe, ON

#### **Description of the Municipal Drinking Water System**

The Port Dover Drinking Water System supplies drinking water to the community of Port Dover. The drinking water system currently serves a population of approximately 7,800. The Port Dover water treatment plant is fed from a surface water source, which is Lake Erie. The water enters a 500mm intake pipe that is located approximately 450m offshore in about 4.3m of water.

The water distribution system includes a 5,000 m<sup>3</sup> elevated tank, which acts as a reservoir when the system requires larger amounts of water than the water treatment plant can supply (such as firefighting and peak flows) and also helps to maintain a constant system pressure. There are approximately 390 fire hydrants and approximately 66,300 meters of water main and transmission main ranging in size from 150 mm to 400mm in diameter. The piping material consists of cast iron, Polyvinyl Chloride (PVC) and ductile iron pipe.



## Water Treatment Chemicals

The following water treatment chemicals were used during the reporting period:

- Sodium Hypochlorite
- Carbon Dioxide
- Poly Aluminum Chloride

## Significant Expenses Incurred

A brief summary of the major expenses incurred during the reporting period to install, repair or replace required equipment, and value of each, is included in Table 1.

Table 1 – Summary of Expenses Incurred

Activity	Cost Incurred (2021)
Port Dover Clarifier Upgrades	\$3,563,628.00
Port Dover Intake Repairs	\$45,440.00
General Operations Maintenance and Repair in Water Treatment Plants and Distribution System	\$96,929.00
Replacement of Watermains	\$2,368,484.00

## 4. Microbiological Testing

### *E. coli* and Total Coliform

As per Schedule 10 of O. Reg. 170/03 – Microbiological Sampling and Testing, bacteriological tests for *E. coli* and total coliforms were performed weekly on the raw and treated water at the facilities and in the distribution system. The results from the 2021 sampling program for the Port Dover Drinking Water are shown in the table below.

Location	Number of Samples	Range of <i>E.coli</i> Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)
Raw	52	0 - 700	0 - 8100
Treated	52	0 - 0	0 - 0
Distribution	233	0 - 0	0 - 51



## Heterotrophic Plate Count (HPC)

As per Schedule 10 of O. Reg. 170/03 - Microbiological Sampling and Testing, HPC analyses are required from the treated and distribution water. HPC tests are required weekly for treated water and for twenty five percent of the required distribution system bacteriological samples. Results over 500 colonies per 1 mL may indicate a change in water quality but is not considered an indicator of unsafe drinking water. The results from the 2021 HPC sampling program for the Port Dover Drinking Water System are shown in the table below.

Location	Number of Samples	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Treated	52	52	<10 - >2000
Distribution	233	71	<10 - 150

## 5. Chemical Testing

The Safe Drinking Water Act requires periodic testing of the water for sixty different chemical parameters. The latest results for these parameters are provided in Appendix A. The sampling frequency varies for the different types of water systems. If the concentration of the parameter is found to be above half of the Maximum Allowable Concentration (MAC) under the Ontario Drinking Water Quality Standards, an increased testing frequency of once every three months is required by Regulation. No additional testing is required for the Port Dover Drinking Water System.

## 6. Operational Monitoring

Operational checks including raw and treated water turbidity and treated and distribution free chlorine were conducted in accordance with Schedule 7 of Reg. O. 170/03.

### Turbidity

The turbidity of the treated water is monitored continuously at each treatment plant; the turbidity of the raw water is checked on a weekly basis. Turbidity is measured in Nephelometric Turbidity Units (NTU). A summary of the 2021 turbidity monitoring results are provided in the table below.



Location	Number of Grab Samples	Range of Results	Unit of Measure
Turbidity Filter 1	8760	0.02 – 0.24	NTU
Turbidity Filter 2	8760	0.02 – 0.36	NTU
Turbidity Filter 3	8760	0.02 – 0.19	NTU

## Chlorine Residual

In accordance with Schedule 7 of O. Reg. 170/03, free chlorine residuals in the treated water are monitored continuously at the point of entry to the distribution system at all water treatment plants and wells. The free chlorine in the water distribution system must be above 0.05 mg/L, if it is below this, it must be reported and corrective actions taken. The results from the 2021 chlorine residual monitoring program for the Port Dover Drinking Water System are shown in the table below.

Location	Number of Grab Samples	Range of Results	Unit of Measure
Chlorine	8760	0.49 – 2.48	mg/L
Chlorine Residual Distribution System	596	0.22 – 1.85	mg/L

## 7. Adverse Results

In accordance with Schedule 16 – Reporting of Adverse Test Results and Other Problems of O. Reg. 170/03, there was one Adverse Water Quality Incident (AWQI) issued for the Port Dover Drinking Water System. The following table describes the date the adverse occurred, the parameter, the result, the corrective action taken and the corrective action date.

Incident Date	Parameter	Result	Corrective Action	Corrective Action Date
13/07/2021	Total Coliform	Weekly Bacteriological Sampling 51 Total Coliform	Check chlorine residuals in the distribution system. Samples were taken at the adverse location, along with one sample up stream and one downstream.	19/07/2020



## APPENDIX A: SUMMARY OF CHEMICAL RESULTS

### UNDERSTANDING CHEMICAL TEST RESULTS

The following tables summarize the laboratory results of the chemical testing Norfolk County is required to complete. Different parameters are required to be tested for at different frequencies as noted below. Results are shown as concentrations with units of either milligrams per litre (mg/L) or micrograms per litre (ug/L). 1 mg/L is equal to 1000 ug/L. The Maximum Acceptable Concentration (MAC) is the highest amount of a parameter that is acceptable in Municipal drinking water and can be found in the MECP Drinking Water Standards. The Method Detection Limit (MDL) is the lowest amount to which the laboratory can confidently measure. There was no additional testing or sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

The following tables summarize the Inorganic parameters tested for during the reporting period or the most recent sample results for the Port Dover Drinking Water System.

#### Port Dover Filtration Plant

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony	04/05/2021	0.9<MDL	ug/L	No
Arsenic	04/05/2021	0.3	ug/L	No
Barium	04/05/2021	23.2	ug/L	No
Boron	04/05/2021	20	ug/L	No
Cadmium	04/05/2021	0.003<MDL	ug/L	No
Chromium	04/05/2021	0.24	ug/L	No
Lead	Exempt			
Mercury	04/05/2021	0.01>MDL	ug/L	No
Selenium	04/05/2021	0.08	ug/L	No
Sodium	04/05/2021	12.4	mg/L	No
Fluoride	04/05/2021	0.12		
Uranium	04/05/2021	0.010	ug/L	No
Nitrite	22/02/2021	0.003<MDL	ug/L	No
	04/05/2021	0.003<MDL	ug/L	No
	16/08/2021	0.003<MDL	ug/L	No
	08/11/2021	0.003<MDL	ug/L	No
Nitrate	22/02/2021	0.428	ug/L	No
	04/05/2021	0.180	ug/L	No
	16/08/2021	0.121	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
	08/11/2021	0.150	ug/L	No

The following tables summarize the Organic parameters tested for during the reporting period or the most recent sample results for the Port Dover Drinking Water.

### Port Dover Filtration Plant

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
<b>Alachlor</b>	04/05/2021	0.02 <MDL	ug/L	No
<b>Atrazine + N-dealkylated metabolites</b>	04/05/2021	0.03 <MDL	ug/L	No
<b>Azinphos-methyl</b>	04/05/2021	0.05 <MDL	ug/L	No
<b>Benzene</b>	04/05/2021	0.32 <MDL	ug/L	No
<b>Benzo(a)pyrene</b>	04/05/2021	0.004 <MDL	ug/L	No
<b>Bromoxynil</b>	04/05/2021	0.33 <MDL	ug/L	No
<b>Carbaryl</b>	04/05/2021	0.05 <MDL	ug/L	No
<b>Carbofuran</b>	04/05/2021	0.01 <MDL	ug/L	No
<b>Carbon Tetrachloride</b>	04/05/2021	0.17 <MDL	ug/L	No
<b>Chlorpyrifos</b>	04/05/2021	0.02 <MDL	ug/L	No
<b>Diazinon</b>	04/05/2021	0.02 <MDL	ug/L	No
<b>Dicamba</b>	04/05/2021	0.20 <MDL	ug/L	No
<b>1,2-Dichlorobenzene</b>	04/05/2021	0.41 <MDL	ug/L	No
<b>1,4-Dichlorobenzene</b>	04/05/2021	0.36 <MDL	ug/L	No
<b>1,2-Dichloroethane</b>	04/05/2021	0.35 <MDL	ug/L	No
<b>1,1-Dichloroethylene (vinylidene chloride)</b>	04/05/2021	0.33 <MDL		
<b>Dichloromethane</b>	04/05/2021	0.35 <MDL	ug/L	No
<b>2-4 Dichlorophenol</b>	04/05/2021	0.15 <MDL	ug/L	No
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>	04/05/2021	0.19 <MDL	ug/L	No
<b>Diclofop-methyl</b>	04/05/2021	0.40 <MDL	ug/L	No
<b>Dimethoate</b>	04/05/2021	0.06 <MDL	ug/L	No
<b>Diquat</b>	04/05/2021	1 <MDL	ug/L	No
<b>Diuron</b>	04/05/2021	0.03 <MDL	ug/L	No



Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Glyphosate	04/05/2021	1 <MDL	ug/L	No
Malathion	04/05/2021	0.02 <MDL	ug/L	No
MCPA	04/05/2021	0.00012 <MDL	mg/L	No
Metolachlor	04/05/2021	0.01 <MDL	ug/L	No
Metribuzin	04/05/2021	0.02 <MDL	ug/L	No
Monochlorobenzene	04/05/2021	0.3 <MDL	ug/L	No
Paraquat	04/05/2021	1 <MDL	ug/L	No
Pentachlorophenol	04/05/2021	0.15 <MDL	ug/L	No
Phorate	04/05/2021	0.01 <MDL	ug/L	No
Picloram	04/05/2021	1 <MDL	ug/L	No
Polychlorinated Biphenyls(PCB)	04/05/2021	0.04 <MDL	ug/L	No
Prometryne	04/05/2021	0.03 <MDL	ug/L	No
Simazine	04/05/2021	0.01 <MDL	ug/L	No
Terbufos	04/05/2021	0.01 <MDL	ug/L	No
Tetrachloroethylene	04/05/2021	0.35 <MDL	ug/L	No
2,3,4,6- Tetrachlorophenol	04/05/2021	0.20 <MDL	ug/L	No
Triallate	04/05/2021	0.01 <MDL	ug/L	No
Trichloroethylene	04/05/2021	0.44 <MDL	ug/L	No
2,4,6- Trichlorophenol	04/05/2021	0.25 <MDL	ug/L	No
Trifluralin	04/05/2021	0.02 <MDL	ug/L	No
Vinyl Chloride	04/05/2021	0.17 <MDL	ug/L	No
Total Haloacetic Acid	22/02/2021	5.3<MDL	ug/L	No
Average below detection 17.2 ug/L	04/05/2021	12.7	ug/L	
	16/08/2021	24.9	ug/L	
	08/11/2021	25.7	ug/L	
THM Annual Average 38 ug/L	22/02/2021	14	ug/L	No
	04/05/2021	22	ug/L	
	16/08/2021	38	ug/L	
	08/11/2021	76	ug/L	





### Microcystin Sample Results

Parameter	Sample Date	Raw Water Results	Treated Water Results	Unit of Measure	Exceedance
<b>Microcystin</b>	6/1/2021	0.1 <MDL	0.1<MDL	Ug/L	No
	6/8/2021	0.1 <MDL	0.1<MDL		
	6/15/2021	0.1<MDL	0.1<MDL		
	6/22/2021	0.1<MDL	0.1<MDL		
	6/29/2021	0.1<MDL	0.1<MDL		
	7/6/2021	0.1<MDL	0.1<MDL		
	7/13/2021	0.1<MDL	0.1<MDL		
	7/20/2021	0.1<MDL	0.1<MDL		
	7/27/2021	0.1<MDL	0.1<MDL		
	8/3/2021	0.1<MDL	0.1<MDL		
	8/10/2021	0.1<MDL	0.1<MDL		
	8/17/2021	0.1<MDL	0.1<MDL		
	8/24/2021	0.1<MDL	0.1<MDL		
	8/31/2021	0.1<MDL	0.1<MDL		
	9/7/2021	0.1<MDL	0.1<MDL		
	9/14/2021	0.1	0.1<MDL		
	9/21/2021	0.1	0.1<MDL		
	9/28/2021	0.1<MDL	0.1<MDL		
	10/5/2021	0.1<MDL	0.1<MDL		
	10/12/2021	0.1<MDL	0.1<MDL		
10/19/2021	0.1<MDL	0.1<MDL			
10/26/2021	0.1<MDL	0.1<MDL			

The following table summarizes the lead testing as set out in Schedule 15.1 of O. Reg. 170/03 during the reporting period.

Location Type	Sample Date	Number of Samples	Range of Lead Results (min#) – (max #) ug/L	Number of Exceedances
<b>Plumbing</b>		Exempt		
<b>Distribution</b>	17/03/2021	3	0.18 – 0.21	0
	12/10/2021	3	0.34 – 0.50	0